



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12206-17-2932
State Number
27518

EQUIPMENT INSPECTED

State Number: 27518	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: VERT EXP	Speed: 80
Landings: 2	Installed: 08/23/2010	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
ASHEVILLE AREA HABITAT FOR HUMANITY	ASHEVILLE AREA HABITAT FOR HUMANITY	
33 MEADOW ROAD	33 MEADOW ROAD	
ASHEVILLE, NC, 28803	ASHEVILLE, NC, 28803	

INSPECTION INFORMATION

Inspection Date 07/24/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.11 Test all elevator smoke detector.

Items must be corrected by: 08/23/2012

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Laura Walker 828-210-9361

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE AREA HABITAT FOR HUMANITY
33 MEADOW ROAD
ASHEVILLE, NC, 28803