



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12209-48-5795
State Number
28424

EQUIPMENT INSPECTED

State Number: 28424	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 14	Manuf: SAVARIA	Speed: 30
Landings: 2	Installed: 07/24/2012	Rope Size:
Volts: 240	Complied:	Entrances: 1
OWNER		OCCUPANT
MARK BRISSON		FRY N PAN
95 S LUMINA AVE UNIT 2H		319 W BAY STREET
WRIGHTSVILLE BEACH, NC, 28408		SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date 07/27/2012	Type Inspection New	Certificate Status Limited	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	------------------------	-------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A 20 DAY LIMITED CERTIFICATE. MOTOR ROOM ACCESS ISSUE [PROVIDE STAIRWAY].

Items must be corrected by: 08/16/2012

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MIKE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MARK BRISSON
95 S LUMINA AVE UNIT 2H
WRIGHTSVILLE BEACH, NC, 28408