



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12221-7-3039
State Number
11204

EQUIPMENT INSPECTED

State Number: 11204	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 07/25/1985	Rope Size:
Volts: 220	Complied: 07/25/1985	Entrances: 1
OWNER	OCCUPANT	
THE GREYSTONE INN	THE GREYSTONE INN	
2663 ROARING GAP DR.	2663 ROARING GAP DR.	
ROARING GAP NC, NC, 28668	ROARING GAP NC, NC, 28668	

INSPECTION INFORMATION

Inspection Date 08/08/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

3

VIOLATIONS

8.11.3.2.1	PERFORM THE ANNUAL RELIEF VALVE TEST
8.6	PROVIDE OPERATION OF THE 1ST AND 3RD FLOOR POSITION INDICATOR LIGHTS

Items must be corrected by: 09/07/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: GREYSTONE IN N 336-363-2211

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE GREYSTONE INN
2663 ROARING GAP DR.
ROARING GAP NC, NC, 28668