N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12227-48-4837
State Number
22692

EQUIPMENT INSPECTED

State Number: **22692**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 03/03/2005	Rope Size: 0
Volts: 0	Complied: 03/03/2005	Entrances: 1

OWNER
ATLANTIC TELEPHONE MEMBERSHIP CORP
620 WHITEVILLE RD
SHALLOTTE, NC, 28459

OCCUPANT
ATLANTIC TELEPHONE MEMBERSHIP CORP
620 WHITEVILLE RD
SHALLOTTE, NC, 28459

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/14/2012	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.13.1[a] Properly maintain hoist way door interlocks or mechanical locks and electric contacts 2ND FL. DR. LOCK HANGING UP SOMETIMES.

Items must be corrected by: 08/24/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Timmy

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ATLANTIC TELEPHONE MEMBERSHIP CORP
620 WHITEVILLE RD
SHALLOTTE, NC, 28459