



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12233-48-2866
State Number
23724

EQUIPMENT INSPECTED

State Number: 23724	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 50
Landings: 4	Installed: 03/10/2006	Rope Size: 0
Volts: 230	Complied: 03/10/2006	Entrances: 1
OWNER	OCCUPANT	
OCEAN WALK HOA	OCEAN WALK CONDO #1	
C/O GO PROPERTY MGMT-G OWEN	105 SE 58TH STREET	
WILMINGTON, NC, 28405	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 08/20/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.27.7.2 Provide the Phase II fire service instructions in the elevator.
8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 09/09/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA
C/O GO PROPERTY MGMT-G OWEN
WILMINGTON, NC, 28405