



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12235-36-5596
State Number
8573

EQUIPMENT INSPECTED

State Number: 8573	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 04/06/1976	Rope Size:
Volts: 460	Complied: 04/06/1976	Entrances: 1
OWNER ALAMANCE-BURLINGTON SCHOOL SYSTEM 1712 VAUGHN RD BURLINGTON, NC, 27215		OCCUPANT ANDREWS ELEMENTARY SCHOOL 2630 BUCKINGHAM RD BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 08/22/2012	Type Inspection Alteration	Certificate Status Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	-------------------------------	------------------------------	---------------------------	--------------------

VIOLATIONS

THIS UNIT IS IN COMPLIANCE THIS DATE 8-22-2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: james

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE-BURLINGTON SCHOOL SYSTEM
1712 VAUGHN RD
BURLINGTON, NC, 27215