



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12236-36-4643
State Number
8128

EQUIPMENT INSPECTED

State Number: 8128	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 07/03/1975	Rope Size:
Volts: 440	Complied: 07/03/1975	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE-BURLINGTON SCHOOL SYSTEM	NEWLIN ELEMENTARY SCHOOL	
1712 VAUGHN RD	316 CARDEN ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 08/23/2012	Type Inspection Alteration	Certificate Status Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	-------------------------------	------------------------------	---------------------------	--------------------

1

VIOLATIONS

THIS UNIT IS IN COMPLIANCE THIS DATE 8-23-2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JAMES

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE-BURLINGTON SCHOOL SYSTEM
1712 VAUGHN RD
BURLINGTON, NC, 27215