N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12263-17-0018
State Number
16690

EQUIPMENT INSPECTED

State Number: **16690**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: AEC
Installed: 06/24/1997
Complied: 06/24/1997

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
AB TECHNICAL COMMUNITY COLLEGE
340 VICTORIA ROAD
ASHEVILLE, NC, 28801

OCCUPANT
AB TECHNICAL/HEMLOCK
340 VICTORIA ROAD
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
09/19/2012	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

8.6.4.7.4 Take steps to eliminate the accumulation of water on the pit floor and remove same.
8.6.4 Remove electrical line in machine room or provide a solide ceiling.

Items must be corrected by: 10/19/2012

Elevator Name: hemlock

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Marty Rice

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
AB TECHNICAL COMMUNITY COLLEGE
340 VICTORIA ROAD
ASHEVILLE, NC, 28801