



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12277-8-4710
State Number
12580

EQUIPMENT INSPECTED

State Number: 12580	Type of Unit: Freight	Floor to Floor: 1 to 4
Capacity: 15000	Manuf: KONE	Speed: 150
Landings: 4	Installed: 07/29/1988	Rope Size: 5/8
Volts: 480	Complied: 08/18/1988	Entrances: 1
OWNER	OCCUPANT	
MALT O MEAL	MALT O MEAL	
2525 BANK ST	2525 BANK ST	
ASHEBORO, NC, 27203	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/03/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.11.1.2	PERFORM ANNUAL NO LOAD GOV & SAFTY TEST (2 ST NOTICE)
2.7.5.1.4	SECURE TOP OF CAR ESCAPE HATCH
8.6.11.1	MAKE FIRE SERVICE KEY SW REMOVEABLE IN ON POSITION
8.6.4.10.1	RESTORE OPERATION OF CAR GATE REVERSING EDGE
8.6.4.13.1	STRIGHTEN BENT HOISTWAY DOOR BOTTOM LANDING
2.13.3.4.9	REPLACE MISSING NO PASSENGER SIGN IN ELEVATOR

Items must be corrected by: 11/02/2012

Elevator Name: OAKMEAL BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: REP- AL SPENCER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MALT O MEAL
2525 BANK ST
ASHEBORO, NC, 27203