



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12278-8-1142
State Number
16142

EQUIPMENT INSPECTED

State Number: 16142	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 8000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 4	Installed: 03/28/1996	Rope Size: 5/8
Volts: 480	Complied: 04/10/1996	Entrances: 1
OWNER	OCCUPANT	
STARPET INC	STARPET INC	
801 PINEVIEW RD	801 PINEVIEW RD	
ASHEBORO, NC, 27203	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/04/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6.4.15	RSTORE OPERATION OF ELEVATOR EMERGENCY PHONE
2.7.5	STRIGHTEN ELEVATOR CAB REAR WALL
8.6.4.15	REPLACE BROKEN OUT EMERGENCY LIGHT FIXTURE

Items must be corrected by: 11/03/2012

Elevator Name: CP BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- JOHN LAYTON

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
STARPET INC
801 PINEVIEW RD
ASHEBORO, NC, 27203