



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12290-48-4449**  
State Number  
**24116**

### EQUIPMENT INSPECTED

State Number: <b>24116</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 10/05/2006	Rope Size: 0
Volts: 208	Complied: 10/05/2006	Entrances: 1

OWNER  
LOGAN HOMES  
60 GREGORY ROAD - SUITE 1  
BELVILLE, NC, 28451

OCCUPANT  
LOGAN OFFICE BLDG  
60 GREGORY ROAD  
BELVILLE, NC, 28451

### INSPECTION INFORMATION

Inspection Date 10/16/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

### VIOLATIONS

- 2.7.2.2.1 Provide clear access to the machine room.
- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 11/05/2012

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Management

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LOGAN HOMES  
60 GREGORY ROAD - SUITE 1  
BELVILLE, NC, 28451