N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12291-52-3716
State Number
10466

EQUIPMENT INSPECTED

State Number: **10466**
Capacity: 2500
Landings: 11
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 09/27/1983
Complied: 10/07/1983

Floor to Floor: L to 10
Speed: 350
Rope Size: 1/2
Entrances: 1

OWNER
SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

OCCUPANT
SUGAR TOP RESORT
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
10/17/2012	Routine	Re-issued	52 - Sosebee	AVERY

6

VIOLATIONS

8.11.2.2.2	Perform an annual no load safety test and provide proper tags.
2.2.5.1	Put the pit lights in proper working order.
2.12.5	Put the car door restricting device in proper working order.
2.14.1.5.1	Make the car top emergency exit operational.
8.6	Perform the annual inspection on the machine room fire extinguisher.

Items must be corrected by: 11/16/2012

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Sugar Top 828-898-5226

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SUGAR TOP HOMEOWNERS
303 SUGAR TOP DRIVE
BANNER ELK, NC, 28604