



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12291-8-355
State Number
9443

EQUIPMENT INSPECTED

State Number: 9443	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: SOUTHERN	Speed: 75
Landings: 2	Installed: 06/13/1979	Rope Size:
Volts: 220	Complied: 06/13/1979	Entrances: 1
OWNER	OCCUPANT	
ACME MCCRARY CORP	ACME MCCRARY CORP	
BOX 1287	159 NORTH STREET	
ASHEBORO, NC, 27204-1287	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/17/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6.4.1 PROVIDE KEY FOR MACHINE ROOM ACCESS

Items must be corrected by: 11/16/2012

Elevator Name: Shipping

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: PERRY COGGINS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ACME MCCRARY CORP
BOX 1287
ASHEBORO, NC, 27204-1287