



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12297-24-3613**  
State Number  
**25984**

EQUIPMENT INSPECTED

State Number: <b>25984</b>	Type of Unit: Passenger	Floor to Floor: 1 to 11
Capacity: 3500	Manuf: SCHINDLER	Speed: 350
Landings: 11	Installed: 09/15/2008	Rope Size: 11mm
Volts: 480	Complied:	Entrances: 1
OWNER		OCCUPANT
60 NORTH MARKET ST. CONDO ASSOCIATION		60 NORTH MARKET STREET
C/O IPM CORP/ ATTN:STEPHANIE CLARK		60 N MARKET STREET
ARDEN, NC, 28704-0580		ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 10/23/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 8.6.1.6.5 Provide a tested up to date class ABC fire extinguisher in machinery space. Last punched date 9/11.
- 8.11.1.5 Making Safety Devices Ineffective. No person shall at any time make any required safety device or electrical protective device ineffective. The door restrictor is a safety device !!!!!!!!!!!
- 2.12.5 Put the car door restricting device in proper working order. 2 ND NOTICE !!!!!!!!!!!

Items must be corrected by: 11/22/2012

Elevator Name: ELEVATOR # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stephanie Clark / 828-650-6875

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

60 NORTH MARKET ST. CONDO ASSOCIATION  
C/O IPM CORP/ ATTN:STEPHANIE CLARK  
ARDEN, NC, 28704-0580