



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12297-48-0393
State Number
24615

EQUIPMENT INSPECTED

State Number: 24615	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 4	Installed: 09/24/2008	Rope Size:
Volts: 208	Complied: 09/24/2008	Entrances: 1
OWNER	OCCUPANT	
CAMS	THE PRESERVE BLDG #4 - CAR 1	
1630 MILITARY CUTOFF RD.	4100 MARSH GROVE LANE	
WILMINGTON,NC, SC, 28403	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 10/23/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 11/12/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CALVIN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAMS
1630 MILITARY CUTOFF RD.
WILMINGTON,NC, SC, 28403