



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12297-48-4790
State Number
24165

EQUIPMENT INSPECTED

State Number: 24165	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SCHINDLER, HYD	Speed: 125
Landings: 4	Installed: 02/28/2007	Rope Size:
Volts: 208	Complied: 02/28/2007	Entrances: 1

OWNER

THE PRESERVE C/O CAMS
1630 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403

OCCUPANT

THE PRESERVE BLD #3 - CAR #1
3100 MARSH GROVE LANE
OAK ISLAND, NC, 24465

INSPECTION INFORMATION

Inspection Date 10/23/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.2.2.4	Install the cover on the sump pump.
8.6.4.7.1	Clean the elevator pit.
N/A	SEAL CUT ON VALVE IN TANK

Items must be corrected by: 11/12/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CALVIN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE PRESERVE C/O CAMS
1630 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403