



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12303-48-4149
State Number
22646

EQUIPMENT INSPECTED

State Number: 22646	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 04/27/2005	Rope Size:
Volts: 208	Complied: 04/27/2005	Entrances: 1
OWNER	OCCUPANT	
KEN CARLOUGH	BRUNSWICK MEDICAL CAMPUS	
1430 COMMONWEALTH DR. SUITE 102	346 OCEAN HIGHWAY WEST	
WILMINGTON, NC, 28403	SUPPLY, NC, 28462	

INSPECTION INFORMATION

Inspection Date 10/29/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.3 Put the Phase II fire service feature in proper working order. [CALL CANCEL BUTTON INOPERATIVE].

Items must be corrected by: 11/18/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

KEN CARLOUGH
1430 COMMONWEALTH DR. SUITE 102
WILMINGTON, NC, 28403