



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12304-48-0299
State Number
25219

EQUIPMENT INSPECTED

State Number: 25219	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 5	Installed: 12/12/2007	Rope Size:
Volts: 206	Complied: 12/12/2007	Entrances: 1

OWNER

REGENCY CONDO HOA CAMS INC.
1630 MILITARY CUTOFF RD. STE 108
WILMINGTON, NC, 28403

OCCUPANT

REGENCY CONDOS BLDG 1
915 SHORELINE DR. W.
SUNSET BEACH, NC, 28467

INSPECTION INFORMATION

Inspection Date 10/30/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.2.5.1	Put the pit lights in proper working order.
2.14.7.1.3	Put the in car emergency light in working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 11/19/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SHEIBY

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

REGENCY CONDO HOA CAMS INC.
1630 MILITARY CUTOFF RD. STE 108
WILMINGTON, NC, 28403