



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12304-8-2471
State Number
8527

EQUIPMENT INSPECTED

| | | |
|---------------------------|-------------------------|------------------------|
| State Number: 8527 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2500 | Manuf: THYSSEN KRUPP | Speed: 125 |
| Landings: 3 | Installed: 11/03/1976 | Rope Size: |
| Volts: 480 | Complied: 02/12/1993 | Entrances: 1 |
| OWNER | OCCUPANT | |
| CAMP CARAWAY | CAMP CARAWAY CONF CNTR | |
| PO BOX 36 | 4756 CARAWAY MT RD | |
| ASHEBORO, NC, 27203 | SOPHIA, NC, 27350 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date 10/30/2012 | Type Inspection Routine | Certificate Status Re-issued | Inspector 8 - Burris | County RANDOLPH |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

76

VIOLATIONS

8.11.1.2 PERFORM ANNUAL PRESSURE RELIEF VALVE TEST & ATTACH TAG TO CONTROLER

Elevator Name: VISITOR/CONFERENCE CTR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- ROSE SKIPPER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAMP CARAWAY
PO BOX 36
ASHEBORO, NC, 27203