N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12310-48-1436
State Number
H1506

EQUIPMENT INSPECTED

State Number: **H1506**
Capacity: 750
Landings: 2
Volts: 110

Type of Unit: Hand Lift
Manuf: SAVARIA
Installed: 03/22/2005
Complied: 03/22/2005

Floor to Floor: 1 to 2
Speed: 25
Rope Size:
Entrances: 2

OWNER
BLADEN CO. SCHOOLS
PO BOX 2519
ELIZABETHTOWN, NC, 28337

OCCUPANT
WEST BLADEN HS PB#4
1600 NC HWY 410
BLADENBORO, NC, 28320

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/05/2012	Routine	Re-issued	48 - Martin	BLADEN

9

VIOLATIONS

8.6.4.13.1[a] Properly maintain hoist way door interlocks or mechanical locks and electric contacts 1ST. FL. DOOR INTERLOCK

Items must be corrected by: 11/15/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: CURLEY

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BLADEN CO. SCHOOLS
PO BOX 2519
ELIZABETHTOWN, NC, 28337