N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12311-48-046
State Number
5122

EQUIPMENT INSPECTED

State Number: **5122**
Capacity: 4000
Landings: 3
Volts: 240

Type of Unit: Passenger
Manuf: WESTBROOK
Installed: 03/05/1965
Complied: 09/16/1994

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
BLADEN CO COURTHOUSE
P O BOX 1626
ELIZABETHTOWN, NC, 28322

OCCUPANT
BLADEN CO COURTHOUSE
200 E. BROAD ST.
ELIZABETHTOWN, NC, 28327

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/06/2012	Routine	Re-issued	48 - Martin	BLADEN

9

VIOLATIONS

3.24.1 Elevator pumping unit. OIL UNDER UNIT

Items must be corrected by: 12/06/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JERRY

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BLADEN CO COURTHOUSE
P O BOX 1626
ELIZABETHTOWN, NC, 28322