



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12314-48-5844**  
State Number  
**16310**

EQUIPMENT INSPECTED

State Number: <b>16310</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/21/1996	Rope Size:
Volts: 208	Complied: 10/03/1996	Entrances: 1
OWNER	OCCUPANT	
OCEAN ISLE BEACH TOWN HALL	OCEAN ISLE BEACH TOWN HALL	
3 W THIRD ST	3 W THIRD ST	
OCEAN ISLE, NC, 27469	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 11/09/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.GETTING RECORDING ONLY

Items must be corrected by: 11/29/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LARRY [MGMT.]

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN ISLE BEACH TOWN HALL  
3 W THIRD ST  
OCEAN ISLE, NC, 27469