N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12320-48-329
State Number
20069

EQUIPMENT INSPECTED

State Number: **20069**
Capacity: 2500
Landings: 3
Volts: 480

Type of Unit: Passenger
Manuf: KONE
Installed: 05/03/2002
Complied: 05/08/2002

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
COMFORT SUITES SOUTHPORT
4963 SOUTHPORT SUPPLY RD
SOUTHPORT, NC, 28291

OCCUPANT
COMFORT SUITES SOUTHPORT
4963 SOUTHPORT SUPPLY RD
SOUTHPORT, NC, 28291

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
11/15/2012	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.2.2.4	Install the cover on the sump pump.
2.27.3.1	Put the Phase I fire service feature in proper working order.
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 12/15/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Lori Millard

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COMFORT SUITES SOUTHPORT
4963 SOUTHPORT SUPPLY RD
SOUTHPORT, NC, 28291