



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12321-33-1296
State Number
10065

EQUIPMENT INSPECTED

State Number: **10065** Type of Unit: Passenger Floor to Floor: M to 14
Capacity: 3500 Manuf: WESTINGHOUSE Speed: 450
Landings: 13 Installed: 03/05/1982 Rope Size: 5/8
Volts: 480 Complied: 04/29/1982 Entrances: 1

OWNER
HINES CHARLOTTE PLAZA LP
201 S COLLEGE ST SUITE 2270
CHARLOTTE, NC, 28244

OCCUPANT
CHARLOTTE PLAZA
201 S. COLLEGE ST.
CHARLOTTE, NC, 28244

INSPECTION INFORMATION

Inspection Date 11/16/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 33 - Dye	County MECKLENBURG	60 D
-------------------------------	----------------------------	---------------------------------	-----------------------	-----------------------	------

VIOLATIONS

- 2.29.1(i) Assign identification (numbers or letters) to the equipment where required.(Designated Landing)
- 2.2.5.1 Put the pit lights in proper working order.
- 8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 12/16/2012

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: Building Management 704 376-4186

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372
An invoice will be mailed to: HINES CHARLOTTE PLAZA LP
201 S COLLEGE ST SUITE 2270
CHARLOTTE, NC, 28244