



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12324-54-4966
State Number
13472

EQUIPMENT INSPECTED

State Number: 13472	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: ESCO	Speed: 120
Landings: 2	Installed: 07/31/1989	Rope Size:
Volts: 240	Complied: 02/11/2002	Entrances: 1
OWNER	OCCUPANT	
BERTIE COUNTY	BERTIE COUNTY OFFICE BLDG	
PO BOX 530	106 DUNDEE ST	
WINDSOR, NC, 27983	WINDSOR, NC, 27983	

INSPECTION INFORMATION

Inspection Date 11/19/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

8.11.3.2.1 Perform the annual relief valve test

Items must be corrected by: 12/19/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ANTHONY

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BERTIE COUNTY
PO BOX 530
WINDSOR, NC, 27983