



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12325-48-055
State Number
20696

EQUIPMENT INSPECTED

State Number: 20696	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 07/22/2002	Rope Size: 0
Volts: 208	Complied: 07/24/1992	Entrances: 1

OWNER
COMMUNITY ASSOCIATION MGMT
CLEARWATER PLACE HOA
WILMINGTON, NC, 28403

OCCUPANT
CLEAR WATER PLACE
1620 GOLEY HEWETT RD.
BOLIVIA, NC, 28422

INSPECTION INFORMATION

Inspection Date 11/20/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.15.2 Replace the cracked, worn, or missing car guides. WORN GUIDES [LOT OF PLAY]. 2ND YR.

Items must be corrected by: 12/10/2012

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MGMT
CLEARWATER PLACE HOA
WILMINGTON, NC, 28403