



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12332-36-4997
State Number
14233

EQUIPMENT INSPECTED

State Number: 14233	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 08/22/1991	Rope Size:
Volts: 460	Complied: 08/22/1991	Entrances: 1

OWNER
KOURY PROPERTIES CENTER
PO BOX 850
BURLINGTON, NC, 27215

OCCUPANT
KOURY MANANGMENT
3060 S CHURCH ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 11/27/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Steve Jentry 336-585-1559

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

KOURY PROPERTIES CENTER
PO BOX 850
BURLINGTON, NC, 27215