



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12335-48-3836
State Number
27106

EQUIPMENT INSPECTED

State Number: 27106	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 125
Landings: 2	Installed: 11/24/2009	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
FIRST BANK	FIRST BANK	
10 WATERFORD BUISNESS CENTER	10 WATERFORD BUSINESS CENTER	
LELAND, NC, 28451	LELAND, NC, 28541	

INSPECTION INFORMATION

Inspection Date 11/30/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 12/30/2012

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JAMI

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST BANK
10 WATERFORD BUISNESS CENTER
LELAND, NC, 28451