



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12346-7-5053
State Number
14783

EQUIPMENT INSPECTED

State Number: 14783	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 09/28/1992	Rope Size:
Volts: 208	Complied: 09/28/1992	Entrances: 1
OWNER	OCCUPANT	
MOUNTAIN VILLAGE APTS	MOUNTAIN VILLAGE APTS	
200 LUTHER ROAD	200 LUTHER RD	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 12/11/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

8.6 PROVIDE OPERATION OF THE CAR POSITION INDICATOR LIGHTS

Items must be corrected by: 01/10/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CRYSTAL WOODS 336-246-9040

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MOUNTAIN VILLAGE APTS
200 LUTHER ROAD
JEFFERSON, NC, 28640