



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**12347-7-0382**  
State Number  
**19072**

EQUIPMENT INSPECTED

State Number: <b>19072</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 2	Installed: 12/19/2000	Rope Size:
Volts: 208	Complied: 12/19/2000	Entrances: 1

OWNER

BALD MOUNTAIN BAPTIST CH  
1460 BALD MTN RD  
W JEFFERSON, NC, 28640

OCCUPANT

BALD MOUNTAIN BAPTIST CH  
1460 BALD MTN RD  
W JEFFERSON, NC, 28640

INSPECTION INFORMATION

Inspection Date 12/12/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

8.11.3.2.1	PERFORM THE ANNUAL RELIEF VALVE TEST
8.6	PERFORM THE FIVE YEAR TEST OF OVER SPEED VALVE IN THE PIT

Items must be corrected by: 01/11/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BALD MTN. BAPTIST CH. 336-877-1550

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BALD MOUNTAIN BAPTIST CH  
1460 BALD MTN RD  
W JEFFERSON, NC, 28640