



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12347-7-1341
State Number
26000

EQUIPMENT INSPECTED

State Number: 26000	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 150
Landings: 3	Installed: 12/03/2008	Rope Size:
Volts: 480	Complied:	Entrances: 1

OWNER

HIGH COUNTRY OF ASHE
203 HAMPTON PLACE COURT
WEST JEFFERSON, NC, 28694

OCCUPANT

HAMPTON INN W JEFFERSON
SOUTH JEFFERSON AVENUE
W JEFFERSON, NC, 28694

INSPECTION INFORMATION

Inspection Date 12/12/2012	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

8.11.3.2.1 PERFORM THE ANNUAL RELIEF VALVE TEST

Items must be corrected by: 01/11/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: HAMPTON INN 910-495-3490

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HIGH COUNTRY OF ASHE
203 HAMPTON PLACE COURT
WEST JEFFERSON, NC, 28694