



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
12348-8-3085
State Number
1167

EQUIPMENT INSPECTED

State Number: **1167**

Capacity: 2000

Landings: 2

Volts: 220

Type of Unit: Freight

Manuf: OTIS

Installed: 10/11/1948

Complied: 10/11/1948

Floor to Floor: 1 to 2

Speed: 75

Rope Size: 1/2

Entrances: 1

OWNER

RANDOLPH CO SENIOR ADULTS ASSOC, INC

PO BOX 1852

ASHEBORO, NC, 28204-1852

OCCUPANT

VACANT

149 NORTH CHURCH ST

ASHEBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date
12/13/2012

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
8 - Burris

County
RANDOLPH

76

VIOLATIONS

8.11.1.2 PERFORM ANNUAL GOVERNOR & SAFTY TEST

8.6 PROVIDE PAD LOCK KEYS FOR ELEVATOR MACHINE ROOM & ROOF LATTER

Items must be corrected by: 01/12/2013

Elevator Name: Plant 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REID GRAIG

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH CO SENIOR ADULTS ASSOC, INC
PO BOX 1852
ASHEBORO, NC, 28204-1852