



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13022-48-4147
State Number
26971

EQUIPMENT INSPECTED

State Number: 26971	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: TKE	Speed: 100
Landings: 2	Installed: 12/17/2009	Rope Size:
Volts: 460	Complied: 12/17/2009	Entrances: 1
OWNER	OCCUPANT	
BLADEN COUNTY COMMUNITY COLLEGE	BLADEN COUNTY STUDENT CENTER	
PO BOX 266	7148 NC 41 WEST	
DUBLIN, NC, 28332	DUBLIN, NC, 28332	

INSPECTION INFORMATION

Inspection Date 01/22/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

n/a No violations found

Items must be corrected by: 02/11/2013

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BLADEN COUNTY COMMUNITY COLLEGE
PO BOX 266
DUBLIN, NC, 28332