



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13031-17-3366
State Number
13037

EQUIPMENT INSPECTED

State Number: 13037	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 05/16/1989	Rope Size:
Volts: 240	Complied: 05/25/1989	Entrances: 1
OWNER	OCCUPANT	
A B TECHNICAL COLLEGE IND ED BLDG	A B TECHNICAL COLLEGE/DOGWOOD	
340 VICTORIA RD	340 VICTORIA RD	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 01/31/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

ncbc Provide in case of fire signs at each elevator lobby.

Items must be corrected by: 03/02/2013

Elevator Name: dogwood

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lee Pack 828-398-7380

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

A B TECHNICAL COLLEGE IND ED BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801