N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13043-36-2532
State Number
15316

EQUIPMENT INSPECTED

State Number: **15316**	Type of Unit: Passenger	Floor to Floor: 2 to 4
Capacity: 4500	Manuf: KONE	Speed: 125
Landings: 3	Installed: 04/14/1994	Rope Size:
Volts: 480	Complied: 05/18/1995	Entrances: 1

OWNER
ALAMANCE REGIONAL MEDICAL CTR
PO BOX 202
BURLINGTON, NC, 27216

OCCUPANT
ALAMANCE REGIONAL MEDICAL CTR
1230 HUFFMAN MILL RD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/12/2013	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Curtis 336-538-7776 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE REGIONAL MEDICAL CTR
PO BOX 202
BURLINGTON, NC, 27216