



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13049-52-4540
State Number
21159

EQUIPMENT INSPECTED

State Number: 21159	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 11/17/2003	Rope Size: 0
Volts: 480	Complied: 11/17/2003	Entrances: 1
OWNER	OCCUPANT	
N.C. DEPARTMENT OF CORRECTIONS	ALEXANDER CORRECTIONAL	
831 WEST MORGAN STREET	633 OLD LANDFILL RD	
RALEIGH, NC, 27603	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 02/18/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

- 2.11.3.1 Adjust the elevator hoistway doors to self close fully. (Top floor.)
- 8.11.1.6 Provide the missing metal tag in the machine room with all pertinent information of the test performed. (Category 1, 3, 5 hydraulic elevators) Relief valve.
- 8.6.1.7.2 Provide A metal tag to the controller for all periodic tests.
- 8.6.5.16.5 Perform the 5 year full load overspeed valve test.

Items must be corrected by: 03/20/2013

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: NC DOC 828-632-1331

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. DEPARTMENT OF CORRECTIONS
831 WEST MORGAN STREET
RALEIGH, NC, 27603