



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13049-52-5170
State Number
21160

EQUIPMENT INSPECTED

State Number: 21160	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 11/17/2003	Rope Size: 0
Volts: 480	Complied: 11/17/2003	Entrances: 1

OWNER

N.C. DEPARTMENT OF CORRECTIONS
831 WEST MORGAN STREET
RALEIGH, NC, 27603

OCCUPANT

ALEXANDER CORRECTIONAL
633 OLD LANDFILL ROAD
TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date 02/18/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

8.11.1.6	Provide the appropriate test tag.(Relief valve.)
5.1.21.1	Put the in car alarm bell in working order.
8.6.5.16.5	Perform the 5 year full load overspeed valve test.
8.6.1.7.2	Provide A metal tag to the controller for all periodic tests.

Items must be corrected by: 03/20/2013

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: NC DOC 828-632-1331

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. DEPARTMENT OF CORRECTIONS
831 WEST MORGAN STREET
RALEIGH, NC, 27603