



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13050-48-0417
State Number
23469

EQUIPMENT INSPECTED

State Number: **23469**

Capacity: 2000

Landings: 3

Volts: 240

Type of Unit: Passenger

Manuf: THYSSEN KRUPP

Installed: 09/08/2005

Complied: 09/09/2005

Floor to Floor: 1 to 3

Speed: 55

Rope Size:

Entrances: 1

OWNER

THE WOODLANDS @ CROW CREEK

10255 BEACH DR SW

CALABASH, NC, 28467

OCCUPANT

CROW CREEK BLDG #6

260 WOODLANDS WAY

CALABASH, NC, 28467

INSPECTION INFORMATION

Inspection Date
02/19/2013

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
48 - Martin

County
BRUNSWICK

10

VIOLATIONS

8.6.4.8.1

Clean the elevator machine room.

8.11.2.2.2

Perform the annual no load safety test

Items must be corrected by: 03/21/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467