



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13050-48-5074
State Number
22317

EQUIPMENT INSPECTED

State Number: 22317	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 2100
Landings: 3	Installed: 10/20/2004	Rope Size:
Volts: 240	Complied: 11/04/2004	Entrances: 1
OWNER	OCCUPANT	
THE WOODLANDS @ CROW CREEK	CROW CREEK CONDOS #4	
10255 BEACH DR SW	280 WOODLANDS WAY, SW	
CALABASH, NC, 28467	CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 02/19/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. 2ND. FL.

2.27.1.1.2 Put the in car emergency telephone in proper working order.

8.11.1.6 Provide a metal with test date, the requirement number requiring the test, and the name of the person or firm performing the test inside the machine room for all Categories 3, 5 tests for electric elevators and 1,3, 5 tests for hydraulic elevators

N/A MOTOR ROOM LIGHT

Items must be corrected by: 03/21/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467