N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13051-48-2619
State Number
23971

EQUIPMENT INSPECTED

State Number: **23971**
Capacity: 2000
Landings: 3
Volts: 230

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 05/17/2006
Complied: 05/17/2006

Floor to Floor: 1 to 3
Speed: 55
Rope Size: 0
Entrances: 1

OWNER
THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467

OCCUPANT
CROW CREEK CONDO #9
235 WOODLANDS WAY
CALABASH, NC, 28467

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
02/20/2013	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 03/22/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
THE WOODLANDS @ CROW CREEK
10255 BEACH DR SW
CALABASH, NC, 28467