

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 13056-36-0868 State Number 6590

		EQUIPMENT INSPECTED			
State Number: 6590 Type of Unit: Passer Capacity: 3500 Manuf: SOUTHER		•	Floor to Floor: 1 to 2 Speed: 75		
Landings: 3	Installed: 06/23	3/1970	Rope Size:		
Volts: 480	Complied: 07/0	01/2003	Entrances: 2	_	
OWNER OCCUPANT		OCCUPANT			
ALAMANCE CO SCHOOLS		CUMMINGS SENIOR HIGH	I SCHOOL		
1712 VAUGHAN RD 2200 MEBANE ST					
BURLINGTON, NC, 27217		BURLINGTON, NC, 27217			
	Г	NSPECTION INFORMATION			
Inspection Date 02/25/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE	
		VIOLATIONS			
2.27.7.1 Provide in case of fire 8.6.1.7.2 A metal tag with the	ency telephone in proper working of e signs at landing. applicable code requirement(s) and ecurely attached to the controller		e of the person or firm perform	ing the test, shall be installed	
Items must be corrected by: Notify the Elevator Bureau in wr complainace with current codes. Violations pointed out to: regina	iting on Corrected Violations Forn	n when the following corrections l	have been made in order to bri		
		mailing address places call: 010.7			
THIS IS NOT AN INVOICE	An invoice will be mailed to:	mailing address please call: 919-7. ALAMANCE CO SCHO 1712 VAUGHAN RD BURLINGTON NC 27	OOLS		