



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13059-16-3923
State Number
25188

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 25188 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2000 | Manuf: T KRUPP, HYD | Speed: 55 |
| Landings: 3 | Installed: 01/24/2008 | Rope Size: 0 |
| Volts: 208 | Complied: 01/24/2008 | Entrances: 1 |

OWNER
BUOY TENDER STATION
PO BOX 265
WASHINGTON, NC, 27889

OCCUPANT
BUOY TENDER
419 W MAIN STREET
WASHINGTON, NC, 27889

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date 02/28/2013 | Type Inspection Routine | Certificate Status Re-issued | Inspector 16 - Moore | County BEAUFORT |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

7

VIOLATIONS

| | |
|------------|---|
| 2.14.7.1.4 | Put the car top light in working order. |
| 8.11.3.2.1 | Perform the annual relief valve test |

Items must be corrected by: 03/30/2013

Elevator Name: elevator # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marsha Rodman / Property Manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BUOY TENDER STATION
PO BOX 265
WASHINGTON, NC, 27889