



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13060-52-0647**  
State Number  
**8022**

#### EQUIPMENT INSPECTED

State Number: **8022**

Capacity: 2000

Landings: 2

Volts: 220

OWNER

AVERY COUNTY

P.O. BOX 640

NEWLAND, NC, 28657

Type of Unit: Passenger

Manuf: THYSSEN KRUPP

Installed: 08/06/1975

Complied: 08/06/1975

OCCUPANT

AVERY COUNTY COURTHOUSE

200 MONTEZUMA STREET

NEWLAND, NC, 28657

Floor to Floor: 1 to 2

Speed: 125

Rope Size: 0

Entrances: 1

#### INSPECTION INFORMATION

Inspection Date  
03/01/2013

Type Inspection  
Routine

Certificate Status  
Re-issued

Inspector  
52 - Sosebee

County  
AVERY

6

#### VIOLATIONS

- 5.1.21.1 Put the in car alarm bell in working order.  
8.6.1.7.2 Provide proper metal tag to the controller for all periodic tests.

Items must be corrected by: 03/31/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery County 828-733-8259

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY  
P.O. BOX 640  
NEWLAND, NC, 28657