



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13060-52-3650**  
State Number  
**28034**

### EQUIPMENT INSPECTED

State Number: <b>28034</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: CANTON	Speed: 100
Landings: 2	Installed: 12/15/2011	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
AVERY COUNTY JAIL ANNEX	AVERY COUNTY JAIL ANNEX	
PO BOX 640	300 SHULTZ CIRCLE	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

### INSPECTION INFORMATION

Inspection Date 03/01/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

### VIOLATIONS

2.11.11.8	Tighten the upthrust devices to operate properly.
8.6.1.7.2	Provide proper metal tag to the controller for all periodic tests.
8.6	Tighten handrail in elevator.
8.11.3.2.1	Perform the annual relief valve and system pressure test.
8.6.4.9	Clean the elevator car top.
8.6	clean jack head to allow oil to flow to buckets.

Items must be corrected by: 03/31/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery county 828-733-8259

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY JAIL ANNEX  
PO BOX 640  
NEWLAND, NC, 28657