



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13063-48-1434
State Number
22560

EQUIPMENT INSPECTED

State Number: 22560	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 300	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 11/18/2004	Rope Size:
Volts: 208	Complied: 11/18/2004	Entrances: 1
OWNER	OCCUPANT	
CAM	ISLANDER RESORT - BLDG. #54	
P.O. BOX 8126	4 VIA DOLOROSA	
OCEAN ISLE BEACH, NC, 28469	OCEAN ISLE BEACH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 03/04/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[k]	Properly maintain door closers, where required. MOTOR ROOM DOOR
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/24/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469