



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13064-36-3982
State Number
25205

EQUIPMENT INSPECTED

State Number: 25205	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 09/25/2007	Rope Size:
Volts: 208	Complied: 09/25/2007	Entrances: 1
OWNER	OCCUPANT	
AMREX	FIVE STAR BUILDING	
MUIRS CHAPEL HILL ROAD	104 E CENTER STREET	
GREENSBORO, NC, 27406	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 03/05/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 8.6.10.1 Update the monthly fire service log.
- 8.6.4.13.2 Where a power-operated horizontally sliding door is closed by momentary pressure or by automatic means, the closing kinetic energy and closing force shall be maintained to proper levels.
- 8.1.6.7.2 A metal tag with the applicable code requirement(s) and date(s) performed, and the name of the person or firm performing the test, shall be installed to be readily visible and securely attached to the controller

Items must be corrected by: 04/05/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: chris hix 828-557-2802

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AMREX
MUIRS CHAPEL HILL ROAD
GREENSBORO, NC, 27406