



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13064-52-4092
State Number
9311

EQUIPMENT INSPECTED

State Number: 9311	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 10/24/1979	Rope Size: 0
Volts: 240	Complied: 10/24/1979	Entrances: 1
OWNER	OCCUPANT	
AVERY COUNTY SCHOOLS	NEWLAND ELEMENTARY SCHOOL	
PO BOX 1360	750 LINVILLE STREET	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

INSPECTION INFORMATION

Inspection Date 03/05/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

8.11.3.2.1 Perfrom the annual relief valve and system pressure test, provide proper metal tag to the controller.

Items must be corrected by: 04/04/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Avery County 828-733-4911

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY SCHOOLS
PO BOX 1360
NEWLAND, NC, 28657