



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13067-52-1395
State Number
H2443

EQUIPMENT INSPECTED

State Number: H2443	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 30
Landings: 2	Installed: 02/21/2013	Rope Size:
Volts: 230	Complied:	Entrances: 2
OWNER	OCCUPANT	
BANNER ELK VISTA PROPERTIES LLC	THE VISTAS	
PO BOX 2074	325 PENNY LANE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 03/08/2013	Type Inspection New	Certificate Status Issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	------------------------	------------------------------	---------------------------	-----------------

6

VIOLATIONS

In Compliance

Elevator Name: 4

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: United Elevator 800-338-0064

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES LLC
PO BOX 2074
BANNER ELK, NC, 28604