N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13073-48-2361
State Number
22009

EQUIPMENT INSPECTED

State Number: **22009**
Capacity: 2000
Landings: 2
Volts: 230

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 01/09/2004
Complied: 01/09/2004

Floor to Floor: 1 to 2
Speed: 65
Rope Size: .
Entrances: 1

OWNER
NANCY & ROLAND GILLIAM
6102 E. OAK ISLAND DR.
OAK ISLAND, NC, 28465

OCCUPANT
MCNEIL CO.
6102 E OAK ISLAND DR
OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
03/14/2013	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 04/13/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: JO JOHNSON

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
NANCY & ROLAND GILLIAM
6102 E. OAK ISLAND DR.
OAK ISLAND, NC, 28465