



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13074-48-2563
State Number
26504

EQUIPMENT INSPECTED

State Number: 26504	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 110
Landings: 2	Installed: 03/18/2009	Rope Size:
Volts: 208	Complied: 03/18/2009	Entrances: 1
OWNER	OCCUPANT	
PARAGON BUILDING CORP	YAUPON BEACH FIRE DEPT	
3811 PEACHTREE AVE STE 100	8500 E OAK ISLAND DRIVE	
WILMINGTON, NC, 28403	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 03/15/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 04/14/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JOHN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PARAGON BUILDING CORP
3811 PEACHTREE AVE STE 100
WILMINGTON, NC, 28403